



सत्यमेव जयते

GOVT. OF ASSAM
OFFICE OF THE DIRECTOR
FIRE AND EMERGENCY SERVICES, ASSAM
PANBAZAR, GUWAHATI



Form - G

UBIN : 290/08225/NOPAN/11/2020

UAIN : FNESBNOCI/2024/00649

NO OBJECTION CERTIFICATE OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN APPLICATION FOR FIRE NOC FOR ONE STORIED / MULTI-STORIED / HIGH RISE BUILDING UNDER ASSAM FIRE SERVICE RULE 1989 (FORM NO I)

Hazard Category: **Low Hazard**

This NOC is issued to **Holy Flower High School** on **18/04/2024** with reference to Compliance Report No. **NIL** dated **11/04/2024**

I here by certify that the building as per description below at **Dag No. 1205,433,994 Patta No. 289,429 Mouza Teok Place Hospital Road Teok, JORHAT** has been inspected in respect of implementation of inbuilt Fire Fighting, Fire Prevention and Means of escape measures and is declared fit in respect of fire safety. The Fire & Emergency Services, Assam has no objection in its occupation/ utilization for the purpose of:

DETAILS OF APPROVED OCCUPATION

S. No.	Floor	Floor Area	Purpose of Utilization
1.	GROUND FLOOR	BLOCK 1 - 462.78 SQM, BLOCK 2 - 332.84 SQM, BLOCK 3 - 300.72 SQM	SCHOOL
2.	FIRST FLOOR	BLOCK 1 - 462.78 SQM, BLOCK 2 - 332.84 SQM, BLOCK 3 - 300.72 SQM	SCHOOL
3.	SECOND FLOOR	BLOCK 2 - 332.84 SQM, BLOCK 3 - 300.72 SQM	SCHOOL

THIS NOC IS VALID UP TO **18/4/2027**

Place of issue : **GUWAHATI**

Date of issue : **18/04/2024**

Director of Fire and Emergency
Services,
Guwahati, Assam

(Subject to Conditions mentioned here under)

CONDITIONS :

1. There should not be any change of Trade for which this License has been issued.
2. There should not be any structural change in the building either horizontally or vertically. There should not also be any change

in the existing arrangements.

3. The fire fighting equipments should be in serviceable condition at all time
4. Water reservoir should always be kept full up to brim
5. The entrance and exit and the water reservoir should always be free from any obstruction/projection.
6. The NOC is liable to be cancelled if the premises (for which the NOC is granted) when inspected are not found conforming to the description and condition under which this NOC is granted.

Director of Fire and Emergency
Services,
Guwahati, Assam



Note : This certificate is computer generated and does not require any Seal/Signature.